



सातारा नगरपरिषद, सातारा

१ केसरकर पेठ, सातारा. ४१५००१

फोन:- (०२१६२) २३४०७६/७७

फॅक्स :- (०२१६२) २३४०७६

ई-मेल :- sataramunicipal@rediffmail.com
municipal_str@dataone.in

जा.क्र.सानप / अग्नि / ४२२५

दिनांक :- ०७/०२/२०२६

FIRE SAFETY CERTIFICATE

Certified That, the Yashoda Public School at NH-4, Wadhe Phata, Satara comprised of One Basement(s) and one (upper floors) owed / occupied by Mr. Dashrath Sagare President Yashoda Shikshan Prasarak Mandal, Satara, Have complied with the fire prevention and fire safety requirement in accordance with rule of state Fire Service Rules, And verified by the officers concerned of fire Service on 07/02/2026 in the presence of Mr. Atul Sagare YSPM and Mr. Rohit Godbole and the building / Premises is fit for occupancy class Group B, Educational Building with effect from 07/02/2026 for the period of 1 years in accordance with rules and subject to compliance of the condition.



Issued on: 07/02/2026 at Satara

Name: Saurabh H Salunke

Designation: Fire Officer
(Satara Municipal Council)

Signature:

To,

Yashoda Public School, Satara

S. No. 244, NH-4, Wadhe Satara

Tal & Dist – Satara, State - Maharashtra

||श्री गणेशाय नमः||

HINDUSTAN TEAMS MARKETING COMPANY

HEAD OFFICE:- GREEN AKARS, DHAMANI ROAD,SANGLI. PH: 9272129189/7276163677/8983615556
EMAIL ID:- hindustanteams@gmail.com , LICENSE NO. MFS-LA/RF-583
AUTHORISED LICENSE AGENCY OF MAHARASHTRA FIRE SERVICES

Ref.No- 08

Date-07/02/2026

(Government Approved licensed agency)
License no. MFS-LA/F-196

FORM B

[See section 3(3) and Rule 4(2)]

Six monthly certifications to be given in every January & July by the occupier for the compliance of the fire prevention and life safety measures.

Certificate

Certified that we have carried out inspection of Fire Prevention and Life Safety Measures installed in the following building or premises, namely: -

We further certify that these installations in above mentioned building are maintained in good repair and efficient conditions during the period **01 January 2026 to 31 December 2027** as required under the provisions of the Maharashtra fire prevention and life safety measures Act 2006 (MAH-III of 2007) The details of the inspections of Installations carried out by us are mentioned in the reports appended herewith.

Description of building or premises.

**YASHODA SHIKSHAN PRASARAK MANDAL'S.,
YASHODA PUBLIC SCHOOL SATARA,
VADHE PHATA, DIST. SATARA.**

The details of the work and rotated activities which I have executed or performed are mentioned in the list appended herewith.

Place: Sangli

Date: 07/02/2026

Digitally signed by
VIVEK BABU
CHOUGULE
VIVEK BABU
CHOUGULE
Date: 2026.02.07
12:18:24 +05'30'

Signature of Inspecting Agency

||श्री गणेशाय नमः||

HINDUSTAN TEAMS MARKETING COMPANY

HEAD OFFICE:- GREEN AKARS, DHAMANI ROAD,SANGLI. PH: 9272129189/7276163677/8983615556
EMAIL ID:- hindustanteams@gmail.com , LICENSE NO. MFS-LA/RF-583
AUTHORISED LICENSE AGENCY OF MAHARASHTRA FIRE SERVICES

Ref.No-Renewal/08

Date- 07/02/2026

ANNEXURE

No.	Details	Qty.
1.	Supply and Installing Electrical Fire Main Pump A. 180 LPM 5 HP Booster Pump	1 SET
2.	Fire Pump Manual Panel with Starter	1SET
3.	Sprinkler system & Courtyard system –	Work Done
4	Fire Extinguisher 5 Kg. A.B.C. CO2 4.5 Kg.	06 02
5	63 mm Single outlet fire hydrant valve ISI, S.S.{ ARMOR MAKE}	4
7	Hose pipe 63mm die with male/ female coupling (15mtr) ISI Premier Brand - A class.{ ARIHANT MAKE}	4
8	M.S.Hose Box 18 Gauges Single door with Glass in front with Lock & Key.	4
9	Providing & Fixing Fire Hose Reel, Wall Mounting Swinging Type Fitted with 30 mm die.30 MTR.. long.	4
10	All short Branch ISI.	4

Place: Sangli

Date: 07/02/2026

Digitally signed by
VIVEK BABU
CHOUGULE
Date: 2026.02.07
12:18:04 +05'30'

Signature of Inspecting Agency